



Product Service

Attestation of Conformity

No. N8A 124191 0004 Rev. 01

Holder of Attestation: **Zhejiang JEC New Energy Technology Co., Ltd.**

1st and 2nd floors of Building 4
CETC Information Industrial Park of
Jiaxing No. 587 Taoyuan Road, Gaozhao Street
Xiuzhou District
314000 Jiaxing City, Zhejiang Province
PEOPLE'S REPUBLIC OF CHINA

Product: **Crystalline Silicon Terrestrial Photovoltaic (PV) Modules**
Mono -Crystalline Silicon Photovoltaic Module

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2014/35/EU relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for conformity assessment. For details see: www.tuvsud.com/ps-cert

Test report no.: 7040624104001-01

Date, 2025-04-29

(Zhulin Zhang)

Page 1 of 2

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.



Product Service

Attestation of Conformity

No. N8A 124191 0004 Rev. 01

Model(s):

NES144-7-xxxM, xxx=540 to 590, in steps of 5
 NES132-7-xxxM, xxx=495 to 540, in steps of 5
 NES120-7-xxxM, xxx=450 to 490, in steps of 5
 NES108-7-xxxM, xxx=405 to 445, in steps of 5
 NES132-8-xxxM, xxx=640 to 720, in steps of 5
 NES120-8-xxxM, xxx=580 to 655, in steps of 5
 NES110-8-xxxM, xxx=545 to 600, in steps of 5
 NES100-8-xxxM, xxx=495 to 545, in steps of 5
 NES80-8-xxxM, xxx=400 to 435, in steps of 5
 xxx is standing for rated output power at STC

Parameters:

Construction:	Framed with Junction box, Cable and Connectors.
Safety Class:	Class II
Maximum System Voltage:	1500 V DC
Fire Safety Class:	Class C according to UL790

Tested according to:

EN IEC 61730-1:2018
 EN IEC 61730-2:2018
 EN IEC 61730-1:2018/AC:2018-06
 EN IEC 61730-2:2018/AC:2018-06

Page 2 of 2

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.