



## CERTIFICATE

No. Z2 124191 0003 Rev. 01

Holder of Certificate: Zhejiang JEC New Energy Technology Co., Ltd.

1st and 2nd floors of Building 4
CETC Information Industrial Park of

Jiaxing No. 587 Taoyuan Road, Gaozhao Street

Xiuzhou District

314000 Jiaxing City, Zhejiang Province PEOPLE'S REPUBLIC OF CHINA

**Certification Mark:** 



Product: Crystalline Silicon Terrestrial Photovoltaic (PV) Modules

Mono -Crystalline Silicon Photovoltaic Module

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition, the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. All applicable requirements of the Testing, Certification, Validation and Verification Regulations of TÜV SÜD Group have to be complied. For details see: www.tuvsud.com/ps-cert

**Test report no.:** 7040624104001-01

**Valid until:** 2030-04-28

**Date**, 2025-04-29

( Zhulin Zhang )



## CERTIFICATE

No. Z2 124191 0003 Rev. 01

Model(s): NES144-7-xxxM, xxx=540 to 590, in steps of 5

NES132-7-xxxM, xxx=495 to 540, in steps of 5 NES120-7-xxxM, xxx=450 to 490, in steps of 5 NES108-7-xxxM, xxx=405 to 445, in steps of 5 NES132-8-xxxM, xxx=640 to 720, in steps of 5 NES120-8-xxxM, xxx=580 to 655, in steps of 5 NES110-8-xxxM, xxx=545 to 600, in steps of 5 NES100-8-xxxM, xxx=495 to 545, in steps of 5 NES80-8-xxxM, xxx=400 to 435, in steps of 5 xxx is standing for rated output power at STC

Parameters: Construction: Framed with Junction box,

Cable and Connectors.

Safety Class: Class II
Maximum System Voltage: 1500 V DC

Fire Safety Class: Class C according to UL790

**Tested IEC** 61215-1:2016 **IEC** 61215-1-1:2016 **IEC** 61215-1-1:2016 **IEC** 61215-2:2016

IEC 61215-2:2016 IEC 61730-1:2016 IEC 61730-2:2016

